

TRANSMISSION SYSTEM ENGINEERING

CONDITIONS OF CERTIFICATION

TSE-1: The project owner shall ensure that the design, construction and operation of the proposed transmission facilities will conform to requirements listed below:

The power plant switchyard, outlet line and termination shall meet or exceed the electrical, mechanical, civil and structural requirements of CPUC General Order 95, CPUC Rule 21, Title 8, California Code of Regulations, Articles 35, 36 and 37 of the "High Voltage Electric Safety Orders", Title 8 CCR, Sections 2700-2974, CPUC Decision 93-11-013, Federal Communications Commission Part 15, Public Resources Code 4292-4296, and National Electric Code (NEC).

Verification: Within 15 days after cessation of construction the project owner shall provide a statement to the CPM from the registered engineer in responsible charge (signed and sealed) that the switchyard and transmission facilities conform to the above-listed requirements.